

TEST REPORT

Issued To: - M/s Mahavir Senior model School Sangam Park Extn ,Rana Partab Bagh G.T. Karnal IRoad, Delhi 110033	Report No:- HLPL20-230727-01
Description Drinking water	Reporting Date:- 31.07.2023
Sample Qty.: - Approx. 1 Ltr.	Sample Received On:- 27. 07.2023
	Sampling By: - Hydel Lab.
	Analysis Start Date:- 27.07.2023
	Analysis End Date:- 31.07.2023

Page. No :- 01 of 01


RESULT

S. No	TEST PARAMETERS (With unit of measurement)	UNIT	TEST RESULT	TEST METHOD	REQUIREMENT AS PER IS:10500:2012	
					ACCEPTABLE LIMIT	PERMISSIBLE LIMIT
General Parameters:-						
1.	pH	-	7.58	IS 3025(P-11)	6.5 to 8.5	No Relaxation
2.	Color, CU	-	<5	IS 3025(P-4)	5	15
3.	Odour	-	Agreeable	IS 3025(P-5)	-	-
4.	Taste	-	Agreeable	IS 3025(P-8)	-	-
5.	Turbidity	NTU	<1	IS 3025(P-10)	1	5
6.	Total Hardness, (as CaCO ₃)	mg/l	130.4	IS 3025(P-21)	200	600
7.	Calcium, (as Ca)	mg/l	40.3	IS 3025(P-40)	75	200
8.	Chloride, (as Cl)	mg/l	19.3	IS 3025(P-32)	250	1000
9.	Residual Free Chlorine	mg/l	ND (DL - 0.05)	IS 3025(P-26)	0.2 Max.	1
10.	Iron, (as Fe)	mg/l	0.006	IS 3025(P-53)	0.3	No Relaxation
11.	Fluoride, (as F)	mg/l	ND (DL - 0.1)	IS 3025(P-60)	1.0	1.5
12.	Alkalinity	mg/l	79.9	IS 3025(P-23)	200	600
13.	Total Dissolved Solid	mg/l	212	IS 3025(P-16)	500	2000

Note: N.D- (Not detected), Values enclosed in brackets are the detection limit.

Remark: The sample confirm to IS: 10500:2012 with Respect to above tests only.

End of Report



For Hydel Laboratories (P) Ltd
Verified BY



Authorized Signatory

Note:-
 • The result indicated only refer to the tested samples and listed parameters and do not endorse any product
 • Total liability of the laboratory is limited to the invoiced amount
 • This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory
 • Samples received shall be destroyed after four weeks from the date of issue of the certificate unless specified otherwise
 • This certificate shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of the laboratory



MUNICIPAL CORPORATION OF DELHI
Public Health Department, Keshav Puram Zone
Office of the Deputy Health Officer
A-1 Block, Keshav Puram, Delhi-110035

75
Azadi Ka
Amrit Mahotsav

No. DHO/KPZ/2023/360

Dated: 17/8/23

SCHOOL HEALTH CERTIFICATE

This is to certify that an inspection team headed by the Public Health Inspector from Public Health Department, Keshav Puram Zone inspected the premises of MAHAVIR SENIOR MODEL SCHOOL, situated at Sangam Park Extn. Rana Pratap Bagh, G.T. Karnal Road, Delhi-110033 on 10.08.2023 and found that the Mahavir Senior Model School has safe drinking water facilities for the students and staff members of the institution and the school is maintaining the hygienic & sanitation condition in the school building/premises.

The above certificate is valid for the period of one year from the date of issuance.

Deputy Health Officer
Keshav Puram Zone



Deputy Health Officer
Keshav Puram Zone
Municipal Corporation of Delhi

Principal
Mahavir Senior Model School
Sangam Park Extn. Rana Pratap Bagh,
G.T. Karnal Road, Delhi-110052.